



miamidade.gov

**Internal Services Department**

111 NW 1<sup>st</sup> Street, Suite 2420  
Miami, Florida 33128  
T 305-375-1129 F 305-375-1125

**ADDENDUM NO. TWO**

**DATE:** May 17, 2016  
**DEPARTMENT:** Internal Services Department (ISD)  
**ISD PROJECT NAME:** Gran Via Elderly Affordable Housing - Additional Parking  
**ISD PROJECT NUMBER:** W160022  
**BID DUE DATE:** **June 1, 2016**  
**CONTRACT COORDINATOR:** Mohammed Taha, CM2

This Addendum is issued to clarify and/or modify the previously issued Invitation to Bid, and is hereby made part of the Contract Documents. All requirements of the Invitation to Bid not modified herein shall remain in full force and effect as originally set forth. **Bidders are required to acknowledge receipt of any and all addenda as instructed in the bid proposal form provided to that effect.**

**MODIFICATIONS**

1. The South Florida Water Management District (SFWMD) Drainage Modification Letter is attached and shall be included with the project's bid documents.

**RESPONSES TO REQUESTS FOR INFORMATION (RFIs):**

**RFI No. 2, submitted by Florida Construction and Engineering, Inc. on 5/12/16**

- Q1. On plan C2.01 are notes saying "contractor to remove existing surface drain grates and place correctly" for the two existing trench drains at the entrances, what is that mean? Please advise.
- A1. The contractor is to remove the heel-proof ductile grate from the trench drain channel and re-install correctly on the trench drain system per the manufacturers (Zurn) installation requirements.

**ALL OTHER PROVISIONS OF THE ORIGINAL INVITATION TO BID REMAIN UNCHANGED.**

Attachments:

SFWMD Drainage Modification Letter

- c: Asael Marrero, AIA, Division Director, ISD  
 Fernando V. Ponassi, MA Arch., LEED®AP, Manager, ISD  
 Daniel Castella, P.E., Project Manager, ISD  
 Jose Montoya, Project Architect, ISD  
 Clerk of the Board